

ANNEXURE C  
Appendix - XIII

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**


No. R.NO 8760/2024

Dated: 15.4.25

It is certified that an inspection team headed by Mr. SHANMUGA PERUMAL, BLOCK HEALTH SUPERVISOR, GOVT. PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT, and Dr. KARTHIKEYAN BLOCK MEDICAL OFFICER GOVT. PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT. DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE inspected the CONCORDIA PUBLIC SCHOOL, NO. 763, MELAKADU, NEAR ALAGU NAGAR, KARAKKOTTAI (PO), MANNARGUDI, THIRUVARUR DISTRICT, TAMILNADU - 614013. on 02.01.2025 checked the water test report submitted by the school and certified that the CONCORDIA PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for a period of one year.

TO  
THE CORRESPONDENT,  
CONCORDIA PUBLIC SCHOOL,  
NO. 763, MELAKADU, NEAR ALAGU NAGAR,  
KARAKKOTTAI (PO), MANNARGUDI,  
THIRUVARUR DISTRICT, TAMILNADU - 614013

  
BLOCK HEALTH SUPERVISOR  
GOVT. PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

  
BLOCK MEDICAL OFFICER  
GOVT. PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

COUNTERSIGNED

  
District Health Officer  
Thiruvapur.



  
Principal  
CONCORDIA PUBLIC SCHOOL  
No. 763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvapur (Dt)

  
Correspondent  
CONCORDIA PUBLIC SCHOOL  
No. 763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvapur (Dt)



ANNEXURE C  
Appendix - XIII

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. *P.00 8760/2024*

Dated: *15.4.25*

It is certified that an inspection team headed by **Mr. SHANMUGA PERUMAL, BLOCK HEALTH SUPERVISOR, GOVT. PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT,** and **Dr. KARTHIKEYAN BLOCK MEDICAL OFFICER GOVT. PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT. DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE** inspected the **CONCORDIA PUBLIC SCHOOL, NO. 763, MELAKADU, NEAR ALAGU NAGAR, KARAKKOTTAI (PO), MANNARGUDI, THIRUVARUR DISTRICT, TAMILNADU - 614013,** on **02.01.2025** checked the water test report submitted by the school and certified that the **CONCORDIA PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid for a period of **one year.**

TO  
THE CORRESPONDENT,  
CONCORDIA PUBLIC SCHOOL,  
NO. 763, MELAKADU, NEAR ALAGU NAGAR,  
KARAKKOTTAI (PO), MANNARGUDI,  
THIRUVARUR DISTRICT, TAMILNADU - 614013

BLOCK HEALTH SUPERVISOR  
GOVT. PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

BLOCK MEDICAL OFFICER  
GOVT. PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

COUNTERSIGNED

Seal

Deputy Director of Health Services office

Thiruvapur

Date : 16 APR 2025

District Health Officer  
Thiruvapur.



*Transfer from Tamil to English*  
*17.4.2025*  
V. JAYAPALAN, B.Sc., B.L.,  
ADVOCATE & NOTARY  
Mannargudi, Thiruvapur Dist.,  
Tamilnadu, India.

Correspondent  
CONCORDIA PUBLIC SCHOOL  
No. 763, Melakadu  
Karakkottai (Po) - 614 013

Mannargudi (Tk), Thiruvapur (Dt).



R.No. 8760/2024

# SANITARY CERTIFICATE

APPENDIX-3  
(chapter III Rule: 24)


I hereby declare that I have inspected the **CONCORDIA PUBLIC SCHOOL, KARAKOTTAI** building and premises on the day of **02.01.2025** and certify.

- ❖ that the accommodation provided for each of the several classes is fairly sufficient for the minimum number of pupils taught there in and is properly ventilated and lighted.
- ❖ that the building is fairly maintained in substantial repair.
- ❖ that is fairly neat and clean.
- ❖ that the latrine and urinal arrangements are good.
- ❖ that the supply of drinking water is wholesome and
- ❖ that in all other necessary aspects the sanitation is good.

**This Certificate is issued subject to the following conditions:**

- ❖ As per rule 3 of the prohibition and smoking and spitting rules 2003, "No Smoking" and "No Spitting" area's board should be displayed in a conspicuous place.
- ❖ This certificate issued is liable to be cancelled at any time on infringement, improper maintenance of buildings and toilets.

**This Certificate is valid for one year from the Date of Issue.**


  
BLOCK HEALTH SUPERVISOR  
GOVT.PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

  
BLOCK MEDICAL OFFICER  
GOVT.PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

COUNTERSIGNED

  
District Health Officer  
Thiruvavarur.



  
Principal  
CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)

  
Correspondent  
CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)



R. No. 8760/2024

# SANITARY CERTIFICATE

APPENDIX-3

(chapter III Rule: 24)

I hereby declare that I have inspected the **CONCORDIA PUBLIC SCHOOL, KARAKOTTAI** building and premises on the day of **02.01.2025** and certify.

- ❖ that the accommodation provided for each of the several classes is fairly sufficient for the minimum number of pupils taught there in and is properly ventilated and lighted.
- ❖ that the building is fairly maintained in substantial repair.
- ❖ that is fairly neat and clean.
- ❖ that the latrine and urinal arrangements are good.
- ❖ that the supply of drinking water is wholesome and
- ❖ that in all other necessary aspects the sanitation is good.

**This Certificate is issued subject to the following conditions:**

- ❖ As per rule 3 of the prohibition and smoking and spitting rules 2003, "No Smoking" and "No Spitting" area's board should be displayed in a conspicuous place.
- ❖ This certificate issued is liable to be cancelled at any time on infringement, improper maintenance of buildings and toilets.

**This Certificate is valid for one year from the Date of Issue.**

BLOCK HEALTH SUPERVISOR  
GOVT.PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

BLOCK MEDICAL OFFICER  
GOVT.PRIMARY HEALTH CENTRE,  
RAYAPURAM  
THIRUVARUR DISTRICT

Seal

COUNTERSIGNED

Deputy Director of Health Services office  
Thiruvavarur

Date : 12 Feb 2025

District Health Officer  
Thiruvavarur.

Principal

CONCORDIA PUBLIC SCHOOL

No.763, Melakadu

Karakkottai (Po) - 614 013

Mannargudi (Tk), Thiruvavarur (Dt)

V.JAYAPALAN, B.Sc., B.L.,  
ADVOCATE & NOTARY  
Mannargudi, Thiruvavarur Dist.,  
Tamilnadu, India.

Correspondent

CONCORDIA PUBLIC SCHO

No.763, Melakadu

Karakkottai (Po) - 614 013

Mannargudi (Tk), Thiruvavarur (Dt)







## TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/25318	Report Issue Date :	15.04.2025	Page No : 01 of 01
Invoice Details:	0050/Dt.04.04. 2025/Amt.Rs.1180/-	ULR No	TC1075123000000200F	

Client Name & Address	: Concordia Public School,
Contact No / Email.ID	763,Melakadu,Karakkottai,
	Mannargudi,Thiruvavarur.

Sample Name	:	Water			
Sample Number	:	25318			
Sample Description	:	RO Plant			
Sample Submitted by	:	Customer			
Location & Date	:	Inside The School Premises ( RO Plant ) & 05.04.2025			
Quantity of sample Received	:	5 Litre			
Sample Container	:	Jerry Cane			
Sample Condition on Receipt	:	Good			
Sample Received On	:	05/04/2025	Environmental Condition	:	23.0°C – 27.0°C
Test Commenced on	:	05/04/2025	Test Completed on	:	15/04/2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	7.09	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025 Part 21-2009	20	200	600
3	Total Alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025-Part 23-2023	28	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	12	250	1000
5	Sulphate as SO <sub>4</sub>	mg/L	IS 3025-Part 24 Sec -01 -2022	4	200	400
6	Nitrate as NO <sub>3</sub>	mg/L	APHA 24th Edition 2023– 4500 –NO <sub>3</sub> B	1	45	45
7	Fluoride as F	mg/L	APHA 24th Edition 2023 – 4500- F-D	0.02	1.0	1.5

Remark: The tested sample Conformed to IS: 10500:2012 Drinking water specification with respect to above tested parameters.

.... End of the report....

Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

## Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Principal

CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)

Correspondent  
CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)



**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 25, Perumal Vadakku Theru, Madapuram, Thiruvavarur – 610001.**

Phone: 04366-221300

E-mail: dwtlthiruvavarur@gmail.com

**TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/25318	Report Issue Date :	15.04.2025	Page 1 of 2
Invoice Details:	0050/Dt.04.04. 2025/Amt.Rs.1180/-			

Client Name & Address Contact No / Email.ID	: Concordia Public School, 763,Melakadu,Karakkottai, Mannargudi,Thiruvavarur.
Sample Name	: Water
Sample Number	: 25318
Sample Description	: RO Plant
Sample Submitted by	: Customer
Location & Date	: Inside The School Premises ( RO Plant ) & 05.04.2025
Quantity of sample Received	: 5 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 05/04/2025
Test Commenced on	: 05/04/2025
Test Completed on	: 15/04/2025
Environmental Condition	: 23.0°C – 27.0°C

S. No	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Colour	IS 3025 Part 4 - 2022	HU	5	5	15
3	Odour	IS 3025 Part 5: 1983	--	None	Agreeable	Agreeable
4	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.4	1	5
5	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	42	500	2000
6	Conductivity	APHA 23rd Edition 2017 – 2510 B	μS/cm	60	-	-
7	P - Alkalinity	IS 3025-Part 23-1983	mg/L	0	-	-
8	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	8	70	200
9	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	3	30	100

S. Kathirkamanathan  
15/4/25  
Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

**Note:**

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

**Principal**

**CONCORDIA PUBLIC SCHOOL**  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)

**Correspondent**

**CONCORDIA PUBLIC SCHOOL**  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)





## DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram, Thiruvavarur – 610001.

Phone: 04366-221300

E-mail: dwtlthiruvavarur@gmail.com

## TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/25318	Report Issue Date :	15.04.2025	Page 2 of 2
Invoice Details:	0050/Dt.04.04. 2025/Amt.Rs.1180/-			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
10	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0.00	0.3	1
11	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0.00	0.1	0.3
12	Ammonia as NH <sub>3</sub>	APHA 17th Edition-1989– 4500 NH <sub>3</sub> C	mg/L	0.00	0.5	0.5
13	Nitrite as NO <sub>2</sub>	APHA 23rd Edition 2017– 4500-NO <sub>2</sub> B	mg/L	0.00	-	-
14	Total Phosphate as PO <sub>4</sub>	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0.00	-	-
15	Sodium	APHA 23rd Edition-2017 – 3500Na B	mg/L	6	-	-
16	Pottasium	APHA 23rd Edition 2017– 3500-K B	mg/L	0	-	-
17	Residual Chlorine	IS/APHA	mg/L	0	0.2	1

Report: The tested sample Conformed to IS: 10500:2012 drinking water specification with respect to above tested parameters.

.....End of the report.....

*S. Kathirkamanathan*  
15/4/25  
Authorised Signatory

S.Kathirkamanathan, B.Sc., MBA-Junior Water Analyst

## Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

*[Signature]*  
Principal

CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)

*[Signature]*  
Correspondent  
CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavarur (Dt)





# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram,  
Thiruvavur - 610001.

Phone: 04366-221300

E-mail: dwtlthiruvavur@gmail.com



TC - 10751

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/25317	Report Issue Date :	15.04.2025	Page No : 01 of 01
Invoice Details:	0050/Dt.04.04. 2025/Amt.Rs.1180/-	ULR No	TC1075123000000199F	

Client Name & Address : Concordia Public School,  
Contact No / Email.ID : 763,Melakadu,Karakkottai,  
Mannargudi,Thiruvavur.

Sample Name	:	Water			
Sample Number	:	25317			
Sample Description	:	Bore Well			
Sample Submitted by	:	Customer			
Location & Date	:	Inside The School Premises & 05.04.2025			
Quantity of sample Received	:	5 Litre			
Sample Container	:	Jerry Cane			
Sample Condition on Receipt	:	Good			
Sample Received On	:	05/04/2025	Environmental Condition	:	23.0°C – 27.0°C
Test Commenced on	:	05/04/2025	Test Completed on	:	15/04/2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	7.14	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025 Part 21-2009	280	200	600
3	Total Alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025-Part 23-2023	192	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	164	250	1000
5	Sulphate as SO <sub>4</sub>	mg/L	IS 3025-Part 24 Sec -01 -2022	36	200	400
6	Nitrate as NO <sub>3</sub>	mg/L	APHA 24th Edition 2023- 4500 -NO3 B	5	45	45
7	Fluoride as F	mg/L	APHA 24th Edition 2023 - 4500- F-D	0.05	1.0	1.5

Remark: The tested sample Conformed to IS: 10500:2012 Drinking water specification with respect to above tested parameters.

.... End of the report....

*Signature*  
15/4/25

Authorised Signatory  
S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

#### Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

**Principal**  
CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavur (Dt)

**Correspondent**  
CONCORDIA PUBLIC SCHOOL  
No.763, Melakadu  
Karakkottai (Po) - 614 013  
Mannargudi (Tk), Thiruvavur (Dt)



**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 25, Perumal Vadakku Theru, Madapuram, Thiruvavur – 610001.****Phone: 04366-221300****E-mail: dwtlthiruvavur@gmail.com****TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/25317	Report Issue Date :	15.04.2025	Page 1 of 2
Invoice Details:	0050/Dt.04.04. 2025/Amt.Rs.1180/-			

Client Name & Address Contact No / Email.ID	: Concordia Public School, 763,Melakadu,Karakkottai, Mannargudi,Thiruvavur.
Sample Name	: Water
Sample Number	: 25317
Sample Description	: Bore Well
Sample Submitted by	: Customer
Location & Date	: Inside The School Premises & 05.04.2025
Quantity of sample Received	: 5 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 05/04/2025
Test Commenced on	: 05/04/2025
Test Completed on	: 15/04/2025
Environmental Condition	: 23.0°C – 27.0°C

S. No	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Colour	IS 3025 Part 4 - 2022	HU	5	5	15
3	Odour	IS 3025 Part 5: 1983	--	None	Agreeable	Agreeable
4	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.7	1	5
5	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	589	500	2000
6	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	842	-	-
7	P - Alkalinity	IS 3025-Part 23-1983	mg/L	0	-	-
8	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	112	70	200
9	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	41	30	100

S. Kathiramanathan  
15/4/25  
Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

**Note:**

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

**Principal**  
**CONCORDIA PUBLIC SCHOOL**  
**No.763, Melakadu**  
**Karakkottai (Po) - 614 013**  
**Mannargudi (Tk), Thiruvavur (Dt)**

**Correspondent**  
**CONCORDIA PUBLIC SCHOOL**  
**No.763, Melakadu**  
**Karakkottai (Po) - 614 013**  
**Mannargudi (Tk), Thiruvavur (Dt)**





**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD**  
**DISTRICT WATER TESTING LABORATORY**  
**No. 25, Perumal Vadakku Theru, Madapuram, Thiruvavarur – 610001.**  
**Phone: 04366-221300 E-mail: dwtlthiruvavarur@gmail.com**

**TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/25317	Report Issue Date :	15.04.2025	Page 2 of 2
Invoice Details:	0050/Dt.04.04. 2025/Amt.Rs.1180/-			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
10	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0.00	0.3	1
11	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0.00	0.1	0.3
12	Ammonia as NH <sub>3</sub>	APHA 17th Edition-1989– 4500 NH <sub>3</sub> C	mg/L	0.00	0.5	0.5
13	Nitrite as NO <sub>2</sub>	APHA 23rd Edition 2017– 4500-NO <sub>2</sub> B	mg/L	0.00	-	-
14	Total Phosphate as PO <sub>4</sub>	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0.00	-	-
15	Sodium	APHA 23rd Edition-2017 – 3500Na B	mg/L	62	-	-
16	Pottasium	APHA 23rd Edition 2017– 3500-K B	mg/L	6	-	-
17	Residual Chlorine	IS/APHA	mg/L	0	0.2	1

Report: The tested sample Conformed to IS: 10500:2012 drinking water specification with respect to above tested parameters.

.....End of the report.....

Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

**Principal**  
**CONCORDIA PUBLIC SCHOOL**  
**No.763, Melakadu**  
**Karakkottai (Po) - 614 013**  
**Mannargudi (Tk), Thiruvavarur (Dt)**

**Correspondent**  
**CONCORDIA PUBLIC SCHOOL**  
**No.763, Melakadu**  
**Karakkottai (Po) - 614 013**  
**Mannargudi (Tk), Thiruvavarur (Dt)**