

Lion. Er. K. VEERA RAMANI B.E., M.I.E., F.I.V.,

**REGISTERED PANEL ENGINEER (CLASS 1 A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT**

**04362 272592
Cell : 94437 84282**

**No. 4, Azhagu Nagar,
Arulananda Nagar 7th Street Extn. (E),
THANJAVUR - 613 007.
E-mail : kvramanitnj@gmail.com**

Date : 1.3.25

BUILDING SAFETY CERTIFICATE

I certify that all the building and structures including Compound wall / Fence in the campus of "Concordia Public School" R.S.No: 527/1, Door No:763, Melakadu, Karakkottai Village and Panchayat, Mannargudi Taluk, Thiruvarur District, have been covered by the stability certificate issued on 01.03.2025 for Three years from 01.06.2025 to 31.05.2028.

And also certified that all structures in the School campus used or unused which is safe for the children.

Place : Thanjavur

Date: 1.3.25



Signature of the Engineer.

**Lion.Er. K. Veera Ramani, B.E., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
No:4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282**



Principal

**CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).**



Correspondent

**CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).**

Lion. Er. K. VEERA RAMANI B.E., M.I.E., F.I.V.,

**REGISTERED PANEL ENGINEER (CLASS 1 A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT**

**04362 272592
Cell : 94437 84282**

**No. 4, Azhagu Nagar,
Arulananda Nagar 7th Street Extn. (E),
THANJAVUR - 613 007.
E-mail : kvramanitnj@gmail.com**

Date : 1.3.25

**Stability Certificate and plan for the Building in
"Concordia Public School"**


**R.S.No: 527/1, Door No:763, Melakadu, Karakkottai Village and Panchayat,
Mannargudi Taluk, Thiruvarur District.**

SL No.	Building	Accomadation Class rooms	Others	Remarks
1	Office room, Class rooms, Lab, Library, Multipurpose Hall, Stage etc.,	600 Nos	-	
2	Toilet Block for Boys and Girls	-	50 Nos	
3	Security Room	-	1 No	
	Total	600 Nos	51 Nos	

TO WHOM SO EVER IT MAY CONCERN

I certify that all the building and structures including Compound wall / Fence in the campus of **"Concordia Public School" R.S.No: 527/1, Door No:763, Melakadu, Karakkottai Village and Panchayat, Mannargudi Taluk, Thiruvarur District** have been covered by the stability certificate issued on **01.03.2025** for Three years **01.06.2025 to 31.05.2028**


Signature of the Engineer.


**K. Veera Ramani, B.E., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
No. 4, Azhagu Nagar, Arulananda Nagar
7th Street Extn. (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282**



Principal

**CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).**



Correspondent

**CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).**

PROCEEDING OF THE DISTRICT COLLECTOR, THANJAVUR

PRESENT : THIRU. A.ANNADURAL, I.A.S

R.C.NO.29449/2016/B1

Date: 10.03.2019

Sub :	Buildings – Tamil Nadu Public Buildings – (Licensing) Act 1965 – application of Thiru.K.Veeraramani to include his name in the panel of Private practicing Engineer under class IA in Thanjavur District – Ordered.
Ref :	1) This Office L.dis.29449/2016/B1/dt.12.09.2016. 2) Engineer-in-Chief, WRD., and Chief Engineer (General), PWD, Chennai Lr.No.AEE/TI/AE-2/22330/2018/Dt.31.10.2018. 3) And other connected records.

++++++

ORDER:

As per the recommendation of Board of Engineers PWD., Chepuk, Chennai in the reference 2nd cited, Thiru.K.Veeraramani B.E., M.I.E., Plat No.4 Azhagu Nagar, Arulananda Nagar Extn (East), Thanjavur is included in the panel of private practicing Engineers under class IA (one A) category in Thanjavur District for the issue of structural soundness Certificate for the public buildings (the cost of which exceeds Rs.50.00 lakhs) under rule 11 of the TamilNadu Public Buildings (Licensing) Act 1965.

Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

Principal
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

To
Thiru.K.VEERA RAMANI B.E., M.I.E.,
Assistant Executive Engineer (Retired),
Public Works Department,
No.4, Azhagu Nagar,
Arulananda Nagar Extn. (East),
Thanjavur 613 007.

District Collector
Thanjavur.

True copy
10/3/19

Lion.Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS IA)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
No.4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282

From:

The Correspondent,
Concordia Public School,
Door No:763, Melakadu,
Karakkottai Village and Panchayat
Mannargudi Taluk,
Thiruvarur District.

To:

The Tahsildar,
Mannargudi.

**THE TAMIL NADU PUBLIC BUILDING LICENSING ACT NO.13 OF 1965 THE
TAMIL NADU PUBLIC BUILDING LICENSE FOR
Concordia Public School**

I intend / to continue to use the existing building for Office room, Class rooms, Lab, Library, Multipurpose Hall, Stage, Security room, Toilet Block for boys and Girls etc., to use the building not at present used as a public building/which is situated in the site or plot or Land, Town or R.S.No: 527/1, Door No:763, Melakadu, Karakkottai Village and Panchayat, Mannargudi Taluk, Thiruvarur District, and specified in the statement enclosed as a public building for a period of Three Years from 01.06.2025 to 31.05.2028.


The year of construction and the present approximate cost of construction and the purpose for which it is to be used or is being used as public building are also furnished in the statement accompanying the application.

I enclosed a challan for Rs. ----- No. ----- Dated ----- in the prescribed form furnished

I also enclosed a certificate of structural soundness issued by

Er. K. Veera Ramani, B.E., M.I.E.,
Panel Engineer
No:4, Azhagu Nagar,
Arulananda Nagar Extn, (East),
Thanjavur -7.
Phone No: 04362-272592. Cell:9443784282

Registration No : **Thanjavur District Collector** in R.C.No: 29449/2016/B1/Dt:10.03.2019
Class 1A (one A) Category



(Signature of the Owner / Occupier of the Building)

Enclosure: (i) Statement
(ii) Chelan for Rs. ----- No. ----- Dated-----
(iii) Form A, B, C, E & Declaration

Explanation: - Separate application shall be made in respect of each building.


Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).



Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).


**STATEMENT ACCOMPANYING
FORM - A**

- | | |
|---|--|
| 1 Name of the Building | : Concordia Public School |
| 2 Location | : Melakadu, Karakkottai Village and Panchayat |
| Street | : |
| Door No of the building | : Door No:763 |
| R.S. No | : R.S.No: 527/1 |
| Ward No | : |
| Name of Place , it | : Melakadu, Karakkottai Village and Panchayat |
| Corporation / Municipality / | : Mannargudi Taluk, Thiruvarur District |
| Panchayat Union / Township | |
| Contonnement. | |
| 3 Year of Construction | : G.F- 2022, F.F - 2025 |
| 4 Approximate cost of construction | : Rs. 2,05,00,000/- |
| 5 Purpose for which the building is being used or proposed to be used. | : Office room, Class rooms, Lab, Library, Multipurpose Hall, Stage etc., |
| 6 Details of construction of the building (Particulars of the foundaion, Soil, Specification of the various part under) | : R.C.C. Framed Structure
Clay mixed with sand |
| 7 | |
| 1 Foundation | : C.C 1:2:4 using 20 mm jelly for column footing and column |
| 2 Basement | : Brick work in Cement mortar / C.C 1:5:10 using 40 mm jelly |
| 3 Superstructure | : Brick work in Cement mortar |
| 4 Floor and Roof | : Tiles flooring, R.C.C Roof |
| 8 Period for which Licenses is required | : Three years 01.06.2025 to 31.05.2028 |
| 9 No. of persons to be accommodated | : 600 Nos |

Signature of the Engineer


Lion Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
 REGISTERED PANEL ENGINEER (CLASS 1A)
 REGISTERED ENGINEER AND
 REGISTERED STRUCTURAL ENGINEER IN
 TOWN AND COUNTRY PLANING DEPARTMENT
 No.6, Azhagu Nagar, Arulananda Nagar
 7th Street Extn., (E), Thanjavur-613 007.
 Phone: (04362)-272592, Cell No: 94437 84282

- 10 I assure that no additional or alteration has been made to the existing building or portion of a building for the application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license on the purpose for which the license was granted for the use of the building or a portion of the changed or altered subsequently.



 (Signature of the Owner / Occupier of the Building)

Date : 01.03.2025

Principal


CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

Correspondent


CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

FORM - B

Form of certificate of a structural under sub section (1) of section 4 of the Tamil Nadu Public Building Licensing Act 1965 referred to in Rule 4 of the Tamil Nadu Public Building (Licensing) Rule 1976

I certify that, I have inspected the building mentioned in the statement and furnished Below its salient technical features.

Office room, Class rooms, Lab, Library, Multipurpose Hall, Stage etc.,

1. FOUNDATION


- | | |
|---|------------------------|
| (I) Depth below ground level | : 1.82 M |
| (II) Nature of Soil met with at Foundation Level | : Clay mixed with sand |
| (III) Pressure at Foundation | : 12.60 Ton / sqm |
| (IV) Probable safe bearing capacity of the strata at foundation | : 20 Ton / sqm |

2. SUPERSTRUCTURES

- | | |
|---|---|
| (I) Maximum stress in the most critical section of Masonry and Concrete | : Column - 120 Ton / sqm
Concrete - 16.20 Ton / sqm |
| (II) Nature of Masonry and concrete and its safe Permissible stress | : CC 1:5:10 using 40mm jelly 100 Ton/sqm.
CC 1:2:4 using 20mm jelly 500 Ton/sqm. |

The Structural soundness of the Building has been verified by me with reference to the I.S.I loading standards 875 (latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.


A license may be granted to utilise the building for the period from **01.06.2025 to 31.05.2028** three years.


Signature of the Engineer

Date : **01.03.2025**

Lion Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
No:4, Azhagu Nayar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282


Principal
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvavur (Dt).


Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvavur (Dt).

FORM-C**STATEMENT TO ACCOMPANY THE CERTIFICATION OF
STRUCTURAL SOUNDNESS**

- 1 Location of the building : **Concordia Public School**
 Location : Melakadu, Karakkottai Village and Panchayat
 Door No of the building : Door No:763
 R.S. No : R.S.No: 527/1
 Ward No :
 Name of the place : Melakadu, Karakkottai Village and Panchayat
 Mannargudi Taluk, Thiruvavarur District
- 2 Age of the Building : G.F - 3 Years, F.F - New Construction
- 3 Number of Storeys : Two Storeyed
- 4 Short description of structure Steel
 R.C.C. framed or Load bearing masonry : R.C.C. Framed Structure
- 5 Purpose for which the building is : Office room, Class rooms, Lab, Library, Multipurpose Hall, Stage etc.,
 certified for use
- 6 The period for which the building : 100 Years
 will be structurally sound
- 7 No. of Persons to be accommodated : 600 Nos
- 8 Remarks : Plan enclosed

Registration No: Thanjavur District Collector in R.C.No: 29449/2016/B1/Dt:10.03.2019

Class 1A (one A) Category

Signature of the Engineer

Date : 01.03.2025

K. Veera Ramani
Mr. Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
 No:4, Azhagu Nayar, Arulananda Nagar
 7th Street Extn., (E), Thanjavur-613 007.
 Phone: (04362)-272592, Cell No: 94437 84282

[Signature]
Principal

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvavarur (Dt).

[Signature]
Correspondent

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvavarur (Dt).

FORM-D

FORM OF LICENCE UNDER SUB-SECTION(1) OF THE SECTION 6 OF THE TAMIL NADU PUBLIC BUILDING (LICENCING) ACT 1965 MADRAS ACT 13 OF 1965 REFERRED TO THE RULE 6 OF THE TAMIL NADU PUBLIC BUILDING LICENSING RULES 1966.

LICENCE NO.27/2022

License renewal is hereby granted to The Correspondent , CONCORDIA PUBLIC SCHOOL, No.763-Melakadu, Karakkottai viilage and panchayat, Mannargudi Taluk in, Survey No:527/1 Tiruvarur District for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned here under.

1. The period of validity of license shall be from 01.06.2025 to 31.05.2028
2. That the building is safely used for the purpose shown in the annexure below.
3. That the building is structurally sound.
4. The building should be used for School purpose only.
5. Fresh license has to be obtained in case of any addition or alteration is made to the existing building or portion of the building.

STATEMENT SHOWING THE DETAILS AND HISTORY OF THE BUILDING

Sl. N o.	Location of the building door no. street name of the building.	Amount Challan No. and date	Nature and Age of the building	Purpose building	Period for building which will be structurally sound	No.of persons accoma-dated
1.	CONCORDIA PUBLIC SCHOOL, No.763-Melakadu, Karakkottai viilage and panchayat , Mannargudi Taluk,	Rs.1000/- Ch.No:20250303009806 Dt:03.03.2025	G.F -3 years F.F-New construction	For School	100 Years	600 Nos

To
The Correspondent ,
CONCORDIA PUBLIC SCHOOL,
No.763-Melakadu, Karakkottai viilage and panchayat,
Mannargudi Taluk,
Thiruvarur Dt.

[Signature]
Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).



[Signature]
15/3/25

Tahsildar
Mannargudi

[Signature]
Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

PROCEEDINGS OF THE TAHSILDAR, MANNARGUDI

Present : Thiru.N. KARTHIC, B.A.,

K.Dis.736/2025/B1

Dated :15.03.2025

Sub: Public Buildings - Licence under Public Buildings Act 1965-
Mannargudi Taluk – CONCORDIA PUBLIC SCHOOL, No.763-
Melakadu, Karakkottai viilage and panchayat, Mannargudi Taluk
,Thiruvarur Dt. – license Renewal for the period from 01.06.2025
To 31.05.2028 Orders issued.

- Ref: 1.Structural Soundness Certificate issued by
Er.K.Veera Ramani,B.E., M.I.V. F.I.V.,
Registered Panel Engineer (Class IA), Registered Structural
Engineer., No:4, Azhagu Nagar., Arulananda Nagar Extn,
Thanjavur. Certificate date:01.03.2025
2. The Correspondent, CONCORDIA PUBLIC SCHOOL,
No.763-Melakadu, Karakkottai viilage and panchayat,
Mannargudi Taluk, Thiruvarur Dt. Application dated:05.03.2025
3. Other connected records.

Order :-


License No.27/2022 under the Tamilnadu Public Building Licensing Act 1965 is renewed to The Correspondent , CONCORDIA PUBLIC SCHOOL, No.763-Melakadu, Karakkottai viilage and panchayat, Mannargudi Taluk in, Survey No:527/1, Tiruvarur District, for the period from 01.06.2025 to 31.05.2028 for School purpose subject to the following condition.



1. Sanitary certificate from Health Department and No objection certificate from Fire service should be renewed every year.

To
The Correspondent ,
CONCORDIA PUBLIC SCHOOL,
No.763-Melakadu, Karakkottai viilage and panchayat,
Mannargudi Taluk,
Thiruvarur Dt..


Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).


Tahsildar
Mannargudi



Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

FORM-D

FORM OF LICENCE UNDER SUB-SECTION(1) OF THE SECTION 6 OF THE TAMIL NADU PUBLIC BUILDING (LICENCING) ACT 1965 MADRAS ACT 13 OF 1965 REFERRED TO THE RULE 6 OF THE TAMIL NADU PUBLIC BUILDING LICENSING RULES 1966.

LICENCE NO.27/2022

License renewal is hereby granted to The Correspondent , CONCORDIA PUBLIC SCHOOL, No.763-Melakadu, Karakkottai viilage and panchayat, Mannargudi Taluk in, Survey No:527/1 Tiruvarur District for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned here under.

1. The period of validity of license shall be from 01.06.2025 to 31.05.2028
2. That the building is safely used for the purpose shown in the annexure below
3. That the building is structurally sound.
4. The building should be used for School purpose only.
5. Fresh license has to be obtained in case of any addition or alteration is made to the existing building or portion of the building.

Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

STATEMENT SHOWING THE DETAILS AND HISTORY OF THE BUILDING

Sl. No.	Location of the building door no. street name of the building.	Amount Challan No. and date	Nature and Age of the building	Purpose building	Period for building which will be structurally sound	No.of persons accommodated
1.	CONCORDIA PUBLIC SCHOOL, No.763-Melakadu, Karakkottai viilage and panchayat , Mannargudi Taluk,	Rs 1000/- Ch.No:20250303009806 Dt:03.03.2025	G.F-3 years F.F-New construction	For School	100 Years	600 Nos

NK 15324
Tahsildar
Mannargudi

To
The Correspondent ,
CONCORDIA PUBLIC SCHOOL,
No.763-Melakadu, Karakkottai viilage and panchayat
Mannargudi Taluk,
Thiruvarur Dt.

Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

True copy Seal
and Panchayat
Translation from
Tamil version to English
V.JAYAPALAN, B.Sc., B.L.,
ADVOCATE & NOTARY
Mannargudi, Thiruvarur Dist.,
Tamilnadu, India.

Tahsildar & Executive Magistrate
MANNARGUDI
Date : 15.03.2025



PROCEEDINGS OF THE TAHSILDAR, MANNARGUDI

Present : Thiru.N. KARTHIC, B.A.,

K.Dis.736/2025/B1

Dated :15.03.2025

Sub: Public Buildings - Licence under Public Buildings Act 1965-
Mannargudi Taluk – CONCORDIA PUBLIC SCHOOL, No.763-
Melakadu, Karakkottai viilage and panchayat, Mannargudi Taluk
,Thiruvarur Dt. – license Renewal for the period from 01.06.2025
To 31.05.2028 Orders issued.

- Ref: 1.Structural Soundness Certificate issued by
Er.K.Veera Ramani,B.E., M.I.V. F.I.V.,
Reggistered Panel Engineer (Class IA)., Registered Structural
Engineer., No:4, Azhagu Nagar., Arulananda Nagar Extn,
Thanjavur. Certificate date:01.03.2025
2. The Correspondent, CONCORDIA PUBLIC SCHOOL,
No.763-Melakadu, Karakkottai viilage and panchayat,
Mannargudi Taluk, Thiruvarur Dt. Application dated:05.03.2025
3. Other connected records.

Order :-

License No.27/2022 under the Tamilnadu Public Building Licensing Act 1965 is renewed to The Correspondent , CONCORDIA PUBLIC SCHOOL, No.763-Melakadu, Karakkottai viilage and panchayat, Mannargudi Taluk in, Survey No:527/1, Tiruvarur District, for the period from 01.06.2025 to 31.05.2028 for School purpose subject to the following condition.

1. Sanitary certificate from Health Department and No objection certificate from Fire service should be renewed every year.

NK 21532
Tahsildar
Mannargudi

To
The Correspondent ,
CONCORDIA PUBLIC SCHOOL,
No.763-Melakadu, Karakkottai viilage and panchayat,
Mannargudi Taluk,
Thiruvarur Dt.

True W.K.J



Principal
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

FORM-E

Form of report to be made to the competent authority by inspecting authority the officers appointed under other Acts Section 28 of the Madras Public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in Rule 7 of the Madras Public Building (Licensing) Rules 1966.

- 1 Name & Designation of the Inspecting authority (or) officer
Appointed or having jurisdiction under any other Act of Law. : **Er. K. Veera Ramani, B.E., M.I.E.,**
Panel Engineer
Assistant Executive Engineer, P.W.D (Retd)
No:4, Azhagu Nagar, Arulananda Nagar Extn,(East),
Thanjavur-7. Phone No: 04362-272592. Cell:9443784282
- 2 Location of the building : **Concordia Public School**
Location : Melakadu, Karakkottai Village and Panchayat
Door No of the building : Door No:763
R.S. No : R.S.No: 527/1
Ward No :
Name of Place , it : Melakadu, Karakkottai Village and Panchayat
Mannargudi Taluk, Thiruvarur District
- 3 Date of inspection : 01.03.2025
- 4 Purpose for which the Building is used : Office room, Class rooms, Lab, Library, Multipurpose Hall, Stage etc.,
- 5 Nature of defects noticed : Nil
- 6 Suggestions for rectifying the defects : Not applicable
- 7 if in dangerous condition immediate : Not applicable
action recommended to be taken.

Signature of the Engineer

K. Veera
Lion. Er. K. Veera Ramani, B.E., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
No:4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282

Date : 01.03.2025

[Signature]
Principal
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

[Signature]
Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

**STATEMENT ACCOMPANYING
FORM - A**

- | | |
|---|--|
| 1 Name of the Building | : Concordia Public School |
| 2 Location | : Melakadu, Karakkottai Village and Panchayat |
| Street | : |
| Door No of the building | : Door No:763 |
| R.S. No | : R.S.No: 527/1 |
| Ward No | : |
| Name of Place , it | : Melakadu, Karakkottai Village and Panchayat |
| Corporation / Municipality / | : Mannargudi Taluk, Thiruvarur District |
| Panchayat Union / Township | |
| Contonnement. | |
| 3 Year of Construction | : 2022 |
| 4 Approximate cost of construction | : Rs. 15,10,000/- |
| 5 Purpose for which the building is being used or proposed to be used. | : Toilet Block for Boys and Girls |
| 6 Details of construction of the building (Particulars of the foundaion, Soil, Specification of the various part under) | : Load bearing masonry
Clay mixed with sand |
| 7 | |
| 1 Foundation | : Brick work in Cement mortar / C.C 1:5:10 using 40 mm jelly |
| 2 Basement | : Brick work in Cement mortar / C.C 1:5:10 using 40 mm jelly |
| 3 Superstructure | : Brick work in Cement mortar |
| 4 Floor and Roof | : Tiles flooring, R.C.C Roof |
| 8 Period for which Licenses is required | : Three years 01.06.2025 to 31.05.2028 |
| 9 No. of persons to be accommodated | : 50 Nos |

Signature of the Engineer

K. Veera
Lion.Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANING DEPARTMENT
No:4, Azhagu Nayar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282

- 10 I assure that no additional or alteration has been made to the existing building or portion of a building for the application has been made. I undertake to obtain a fresh license in case any addition or aleration is made to the existing building or portion of the building. I also undertake to obtain a fresh license on the purpose for which the license was granted for the use of the building or a portion of the changed or altered subsequently.

[Signature]
 (Signature of the Owner / Occupier of the Building)

Date : 01.03.2025

[Signature]
Principal
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

[Signature]
Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

FORM - B

Form of certificate of a structural under sub section (1) of section 4 of the Tamil Nadu Public Building Licensing Act 1965 referred to in Rule 4 of the Tamil Nadu Public Building (Licensing) Rule 1976

I certify that, I have inspected the building mentioned in the statement and furnished Below its salient technical features.

Toilet Block for Boys and Girls**1. FOUNDATION**

- | | |
|---|------------------------|
| (I) Depth below ground level | : 1.52 M |
| (II) Nature of Soil met with at Foundation Level | : Clay mixed with sand |
| (III) Pressure at Foundation | : 7.60 Ton / sqm |
| (IV) Probable safe bearing capacity of the strata at foundation | : 20 Ton / sqm |

2. SUPERSTRUCTURES


- | | |
|---|--|
| (I) Maximum stress in the most critical section of Masonry and Concrete | : Masonry - 6.20 Ton / sqm
Concrete - 4.70 Ton / sqm |
| (II) Nature of Masonry and concrete and its safe Permissible stress | : CC 1:5:10 using 40mm jelly 100 Ton/sqm.
Brick work in Cement mortar 50 Ton/sqm. |


The Structural soundness of the Building has been verified by me with reference to the I.S.I loading standards 875 (latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.

A license may be granted to utilise the building for the period from **01.06.2025 to 31.05.2028** three years.


Signature of the Engineer

Date : **01.03.2025**


Lion. Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANING DEPARTMENT
 No:4, Azhagu Nayar, Arulananda Nagar
 7th Street Extn., (E), Thanjavur-610 001
 Phone: (04362)-272592, Cell No: 94437 34282


Principal

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).


Correspondent

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

FORM-C**STATEMENT TO ACCOMPANY THE CERTIFICATION OF
STRUCTURAL SOUNDNESS**

- 1 Location of the building : **Concordia Public School**
 Location : Melakadu, Karakkottai Village and Panchayat
 Door No of the building : Door No:763
 R.S. No : R.S.No: 527/1
 Ward No :
 Name of the place : Melakadu, Karakkottai Village and Panchayat
 Mannargudi Taluk, Thiruvarur District
- 2 Age of the Building : 3 Years
- 3 Number of Storeys : Single Storeyed
- 4 Short description of structure Steel
 R.C.C. framed or Load bearing masonry : Load bearing masonry
- 5 Purpose for which the building is : Toilet Block for Boys and Girls
 certified for use
- 6 The period for which the building : 50 Years
 will be structurally sound
- 7 No. of Persons to be accommodated : 50 Nos
- 8 Remarks : Plan enclosed

Registration No: Thanjavur District Collector in R.C.No: 29449/2016/B1/Dt:10.03.2019
 Class 1A (one A) Category

Signature of the Engineer

Date : 01.03.2025

K.V.R.
Lion.Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
 REGISTERED PANEL ENGINEER (CLASS 1A)
 REGISTERED ENGINEER AND
 REGISTERED STRUCTURAL ENGINEER IN
 TOWN AND COUNTRY PLANNING DEPARTMENT
 No:4, Azhagu Nagar, Aruiananda Nagar
 7th Street Extn.. (E), Thanjavur-613 007.
 Phone: (04362)-272592, Cell No: 94437 84282

[Signature]
Principal

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

[Signature]


Correspondent

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

FORM-E

Form of report to be made to the competent authority by inspecting authority the officers appointed under other Acts Section 28 of the Madras Public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in Rule 7 of the Madras Public Building (Licensing) Rules 1966.

- 1 Name & Designation of the Inspecting authority (or) officer Appointed or having jurisdiction under any other Act of Law. : **Er. K. Veera Ramani, B.E., M.I.E.,**
Panel Engineer
Assistant Executive Engineer, P.W.D (Retd)
No:4, Azhagu Nagar, Arulananda Nagar Extn,(East),
Thanjavur-7.Phone No: 04362-272592. Cell:9443784282
- 2 Location of the building : **Concordia Public School**
Location : Melakadu, Karakkottai Village and Panchayat
Door No of the building : Door No:763
R.S. No : R.S.No: 527/1
Ward No :
Name of Place , it : Melakadu, Karakkottai Village and Panchayat
Mannargudi Taluk, Thiruvarur District
- 3 Date of inspection : 01.03.2025
- 4 Purpose for which the Building is used : Toilet Block for Boys and Girls
- 5 Nature of defects noticed : Nil
- 6 Suggestions for rectifying the defects : Not applicable
- 7 if in dangerous condition immediate action recommended to be taken. : Not applicable



Signature of the Engineer

Date : 01.03.2025

Lion.Er. K. Veera Ramani, B.E., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANING DEPARTMENT
No:4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282


Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).


Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

STATEMENT ACCOMPANYING**FORM - A**

- | | |
|---|--|
| 1 Name of the Building | : Concordia Public School |
| 2 Location | : Melakadu, Karakkottai Village and Panchayat |
| Street | : |
| Door No of the building | : Door No:763 |
| R.S. No | : R.S.No: 527/1 |
| Ward No | : |
| Name of Place , it | : Melakadu, Karakkottai Village and Panchayat |
| Corporation / Municipality / | : Mannargudi Taluk, Thiruvarur District |
| Panchayat Union / Township | |
| Contonnement. | |
| 3 Year of Construction | : 2025 |
| 4 Approximate cost of construction | : Rs. 8,00,000/- |
| 5 Purpose for which the building is being used or proposed to be used. | : Security room |
| 6 Details of construction of the building (Particulars of the foundaion, Soil, Specification of the various part under) | : Load bearing masonry
Clay mixed with sand |
| 7 | |
| 1 Foundation | : Brick work in Cement mortar / C.C 1:5:10 using 40 mm jelly |
| 2 Basement | : Brick work in Cement mortar / C.C 1:5:10 using 40 mm jelly |
| 3 Superstructure | : Brick work in Cement mortar |
| 4 Floor and Roof | : Cement flooring, R.C.C Roof |
| 8 Period for which Licenses is required | : Three years 01.06.2025 to 31.05.2028 |
| 9 No. of persons to be accommodated | : 1 No |

Signature of the Engineer



Lion. Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANING DEPARTMENT
No:4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282

- 10 I assure that no additional or alteration has been made to the existing building or portion of a building for the application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license on the purpose for which the license was granted for the use of the building or a portion of the changed or altered subsequently.

(Signature of the Owner / Occupier of the Building)

Date : **01.03.2025****Principal**

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

**Correspondent**

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

FORM - B

Form of certificate of a structural under sub section (1) of section 4 of the Tamil Nadu Public Building Licensing Act 1965 referred to in Rule 4 of the Tamil Nadu Public Building (Licensing) Rule 1976

I certify that, I have inspected the building mentioned in the statement and furnished Below its salient technical features.

Security room**1. FOUNDATION**

- | | |
|---|------------------------|
| (I) Depth below ground level | : 1.52 M |
| (II) Nature of Soil met with at Foundation Level | : Clay mixed with sand |
| (III) Pressure at Foundation | : 7.10 Ton / sqm |
| (IV) Probable safe bearing capacity of the strata at foundation | : 20 Ton / sqm |

2. SUPERSTRUCTURES

- | | |
|---|--|
| (I) Maximum stress in the most critical section of Masonry and Concrete | : Masonry - 7.50 Ton / sqm
Concrete - 5.20 Ton / sqm |
| (II) Nature of Masonry and concrete and its safe Permissible stress | : CC 1:5:10 using 40mm jelly 100 Ton/sqm.
Brick work in Cement mortar 50 Ton/sqm. |


The Structural soundness of the Building has been verified by me with reference to the I.S.I loading standards 875 (latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.


A license may be granted to utilise the building for the period from 01.06.2025 to 31.05.2028 three years.

Signature of the Engineer

Date : 01.03.2025


Lion. Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
 REGISTERED PANEL ENGINEER (CLASS 1A)
 REGISTERED ENGINEER AND
 REGISTERED STRUCTURAL ENGINEER IN
 TOWN AND COUNTRY PLANNING DEPARTMENT
 No: 4, Azhagu Nagar, Aruiananda Nagar
 7th Street Extn., (E), Thanjavur-613 007.
 Phone: (04362)-272592, Cell No: 94437 84292


Principal
CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No. 763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvannamalai


Correspondent
CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No. 763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvannamalai

FORM-C**STATEMENT TO ACCOMPANY THE CERTIFICATION OF
STRUCTURAL SOUNDNESS**

- 1 Location of the building : **Concordia Public School**
 Location : Melakadu, Karakkottai Village and Panchayat
 Door No of the building : Door No:763
 R.S. No : R.S.No: 527/1
 Ward No :
 Name of the place : Melakadu, Karakkottai Village and Panchayat
 Mannargudi Taluk, Thiruvarur District
- 2 Age of the Building : New Construction
- 3 Number of Storeys : Single Storeyed
- 4 Short description of structure Steel
 R.C.C. framed or Load bearing masonry : Load bearing masonry
- 5 Purpose for which the building is : Security room
 certified for use
- 6 The period for which the building : 50 Years
 will be structurally sound
- 7 No. of Persons to be accommodated : 1 No
- 8 Remarks : Plan enclosed

Registration No: Thanjavur District Collector in R.C.No: 29449/2016/B1/Dt:10.03.2019

Class 1A (one A) Category

Signature of the Engineer

Date : 01.03.2025

KVR
Lion.Er. K. Veera Ramani, BE., M.I.E., F.I.V.,
 REGISTERED PANEL ENGINEER (CLASS 1A)
 REGISTERED ENGINEER AND
 REGISTERED STRUCTURAL ENGINEER IN
 TOWN AND COUNTRY PLANNING DEPARTMENT
 No:4, Azhagu Nayar, Arulananda Nagar
 7th Street Extn., (E), Thanjavur-613 007.
 Phone: (04362)-272592, Cell No: 94437 84282

SG
Principal

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

Correspondent
Correspondent


CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvarur (Dt).

FORM-E

Form of report to be made to the competent authority by inspecting authority the officers appointed under other Acts Section 28 of the Madras Public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in Rule 7 of the Madras Public Building (Licensing) Rules 1966.


- 1 Name & Designation of the Inspecting authority (or) officer Appointed or having jurisdiction under any other Act of Law. : **Er. K. Veera Ramani, B.E., M.I.E.,**
Panel Engineer
Assistant Executive Engineer, P.W.D (Retd)
No:4, Azhagu Nagar, Arulananda Nagar Extn,(East),
Thanjavur-7.Phone No: 04362-272592. Cell:9443784282
- 2 Location of the building : **Concordia Public School**
Location : Melakadu, Karakkottai Village and Panchayat
Door No of the building : Door No:763
R.S. No : R.S.No: 527/1
Ward No :
Name of Place , it : Melakadu, Karakkottai Village and Panchayat
Mannargudi Taluk, Thiruvarur District
- 3 Date of inspection : 01.03.2025
- 4 Purpose for which the Building is used : Security room
- 5 Nature of defects noticed : Nil
- 6 Suggestions for rectifying the defects : Not applicable
- 7 if in dangerous condition immediate action recommended to be taken. : Not applicable

Signature of the Engineer




Date : 01.03.2025

Lion. Er. K. Veera Ramani, B.E., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANNING DEPARTMENT
No:4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 017
Phone: (04362)-272592, Cell No: 94437 84282



Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).



Correspondent


CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

DECLARATION

Er. K. Veera Ramani son of **V. Kathiresan** Residing at No:4, Azhagu Nagar, Arulananda Nagar Extn, (East), Thanjavur -7. do hereby declare that I posses the qualification and experience specified in the Table to rule 11 of the Tamil Nadu Public Buildings (License) rules 1965 and also approved in the panel of Private Practicing Engineers under **Class 1A (one A) Category in Thanjavur District Collector R.C.No: 29449/2016/B1/Dt:10.03.2019** for issuing the certificate of structural soundness for the Public buildings covered by the certificate under rule 11 of the Tamil Nadu Public Buildings (Licensing) Act 1965.

Remarks:

1. This certificate does not holds or ensures the responsibility for the stability of the building structure due to Natural Calamities like Earth Quake, Gale Cyclone, Fire and Tsunami.
2. The subsequent addition and alteration of the building should be done only with prior information to the certifying authority


Signature of the Engineer,

Station: Thanjavur

Date: 1.3.25

Er. K. Veera Ramani, B.E., M.I.E., F.I.V.,
REGISTERED PANEL ENGINEER (CLASS 1A)
REGISTERED ENGINEER AND
REGISTERED STRUCTURAL ENGINEER IN
TOWN AND COUNTRY PLANING DEPARTMENT
No:4, Azhagu Nagar, Arulananda Nagar
7th Street Extn., (E), Thanjavur-613 007.
Phone: (04362)-272592, Cell No: 94437 84282


1. Name & Address of Panel Engineer

Er. K. Veera Ramani, B.E., M.I.E.,
Panel Engineer
No:4, Azhagu Nagar,
Arulananda Nagar Extn,(East),
Thanjavur -7.
Phone No: 04362-272592. Cell:9443784282

2. Experience of Panel Engineer

:25 years of Experiences in Government side and 10 years of private practice as Consulting Engineer and Private Practicing Engineer from 2008


Principal
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).


Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).