

ANNEXURE C

Appendix – XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY

CONDITION CERTIFICATE

No. 174/2026

Dated: 11.03.26

It is certified that an inspection team headed by Mr.SIVAKUMAR, BLOCK HEALTH SUPERVISOR, GOVT.PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT, and Dr.NIVAS S BLOCK MEDICAL OFFICER GOVT. PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT, DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE inspected The CONCORDIA PUBLIC SCHOOL, NO, 763, MELAKADU, NEAR ALAGU NAGAR, KARAKKOTTAI (PO), MANNARGUDI, THIRUVARUR DISTRICT, TAMILNADU - 614013 on 11.02.2026 and checked the water test report submitted by the school and certified that the CONCORDIA PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt. This certificate is valid for a period of one year.

TO

THE CORRESPONDENT,
CONCORDIA PUBLIC SCHOOL,
NO. 763, MELAKADU, NEAR ALAGU NAGAR,
KARAKKOTTAI (PO), MANNARGUDI,
THIRUVARUR DISTRICT, TAMILNADU – 614013

BLOCK HEALTH SUPERVISOR
GOVT.PRIMARY HEALTH CENTRE,
RAYAPURAM
THIRUVARUR DISTRICT

BLOCK MEDICAL OFFICER
GOVT.PRIMARY HEALTH CENTRE,
RAYAPURAM
THIRUVARUR DISTRICT



[Signature]

Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvapur (Dt).

[Signature]
11/3/26

[Signature]

Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvapur (Dt).

ANNEXURE C

Appendix – XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY

CONDITION CERTIFICATE

No. 174/2026

Dated: 11.03.26

It is certified that an inspection team headed by Mr.SIVAKUMAR, BLOCK HEALTH SUPERVISOR, GOVT.PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT, and Dr.NIVAS S BLOCK MEDICAL OFFICER GOVT. PRIMARY HEALTH CENTRE, RAYAPURAM, THIRUVARUR DISTRICT, DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE inspected The CONCORDIA PUBLIC SCHOOL, NO, 763, MELAKADU, NEAR ALAGU NAGAR, KARAKKOTTAI (PO), MANNARGUDI, THIRUVARUR DISTRICT, TAMILNADU - 614013 on 11.02.2026 and checked the water test report submitted by the school and certified that the CONCORDIA PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt. This certificate is valid for a period of one year.

TO
THE CORRESPONDENT,
CONCORDIA PUBLIC SCHOOL,
NO. 763, MELAKADU, NEAR ALAGU NAGAR,
KARAKKOTTAI (PO), MANNARGUDI,
THIRUVARUR DISTRICT, TAMILNADU – 614013

M. S. S. 11/3/26
BLOCK HEALTH SUPERVISOR
GOVT.PRIMARY HEALTH CENTRE,
RAYAPURAM
THIRUVARUR DISTRICT

A. D. S. 11/3/26
BLOCK MEDICAL OFFICER
GOVT.PRIMARY HEALTH CENTRE,
RAYAPURAM
THIRUVARUR DISTRICT

*Translation from
Tamil version to
English*
20.5.2026

Seal

Government Primary Health Centre
Rayapuram-612803, Thiruvapur
Date : 11.03.2026

J.R.
Principal

V.JAYAPALAN, B.Sc., B.L.,
ADVOCATE & NOTARY
Mannargudi, Thiruvapur Dist.,
Tamilnadu, India.

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744



Correspondent
CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No. 763, Melakadu

Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvapur (Dt).

Karakkottai (Po), Thiruvapur (Dt).
Mannargudi (Tk), Thiruvapur (Dt).



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TVR24813

Issued Date : 10-02-2026

Organization Type : Educational Institutions

Expiry Date : 09-02-2027

Name of the Organization : CONCORDIA PUBLIC SCHOOL

Address : NO.763,MELAKADU, NEAR ALAGU

NAGAR,KARAKKOTTAI PO,MANNARGUDI,THIRUVARUR DISTRICT

I, **UDHAYA BANU M** owner/manager of the **CONCORDIA PUBLIC SCHOOL** functioning as **Educational Institutions** located at **Karakkottai** in **Thiruvavarur** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **10-02-2026** to **09-02-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **250** people/pupils and has **12** urinals and **18** toilets which is proportionate to the number of users as per government norms.
- **4** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00126TVR24813 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TVR24813 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.

Principal

Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvavarur (Dt).

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvavarur (Dt).



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram,
Thiruvarur – 610001.

Phone: 04366-221300

E-mail: dwtlthiruvarur@gmail.com



TC – 10751

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25434	Report Issue Date :	27.01.2026	Page No : 01 of 01		
Invoice Details:	0121/Dt.23.01. 2026/Amt.Rs.1652/-	ULR No	TC1075126000000277F			
Client Name & Address		: Concordia Public School, 763,Mela Kadu,Near Alagar Nagar, Karikottai,Mannargudi.				
Contact No / Email.ID						
Sample Name	:	Water				
Sample Number	:	25434				
Sample Description	:	RO Unit				
Sample Submitted by	:	Bakkiya				
Location & Date	:	Inside The Campus & 23.01.2026				
Quantity of sample Received	:	2 Litre				
Sample Container	:	Jerry Cane				
Sample Condition on Receipt	:	Good				
Sample Received On	:	23/01/2026	Environmental Condition	: 23.0°C – 27.0°C		
Test Commenced on	:	23/01/2026	Test Completed on	: 27/01/2026		
S.No.	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	7.15	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	76	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-2023	48	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	20	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24 Sec -01 -2022	45	200	400
6	Nitrate as NO ₃	mg/L	APHA 24th Edition 2023– 4500 –NO3 B	7	45	45
7	Fluoride as F	mg/L	APHA 24th Edition 2023 – 4500- F-D	0.20	1.0	1.5

Remark: The tested sample Conformed to IS: 10500:2012 Drinking water specification with respect to above tested parameters.

.... End of the report....

Authorised Signatory


S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.


Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).


Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 25, Perumal Vadakku Theru, Madapuram, Thiruvarur – 610001.****Phone: 04366-221300****E-mail: dwtlthiruvarur@gmail.com****TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25434	Report Issue Date :	27.01.2026	Page 1 of 2
Invoice Details:	0121/Dt.23.01. 2026/Amt.Rs.1652/-			

Client Name & Address Contact No / Email.ID	: Concordia Public School, 763,Mela Kadu,Near Alagar Nagar, Karikottai,Mannargudi.
Sample Name	: Water
Sample Number	: 25434
Sample Description	: RO Unit
Sample Submitted by	: Bakkiya
Location & Date	: Inside The Campus & 23.01.2026
Quantity of sample Received	: 2 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 23/01/2026
Test Commenced on	: 23/01/2026
Test Completed on	: 27/01/2026
Environmental Condition	: 23.0°C – 27.0°C

S. No	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Colour	IS 3025 Part 4 - 2022	HU	5	5	15
3	Odour	IS 3025 Part 5: 1983	--	None	Agreeable	Agreeable
4	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.1	1	5
5	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	175	500	2000
6	Conductivity	APHA 23rd Edition 2017 – 2510 B	μS/cm	250	-	-
7	P - Alkalinity	IS 3025–Part 23-1983	mg/L	0	-	-
8	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	30	70	200
9	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	11	30	100

Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.

Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram, Thiruvapur - 610001.

Phone: 04366-221300

E-mail: dwtlthiruvapur@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25434	Report Issue Date :	27.01.2026	Page 2 of 2
Invoice Details:	0121/Dt.23.01. 2026/Amt.Rs.1652/-			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
10	Iron as Fe	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0	0.3	1
11	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.1	0.3
12	Ammonia as NH ₃	APHA 17th Edition-1989- 4500 NH ₃ C	mg/L	0.00	0.5	0.5
13	Nitrite as NO ₂	APHA 23rd Edition 2017- 4500-NO ₂ B	mg/L	0.00	-	-
14	Total Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.00	-	-
15	Sodium	APHA 23rd Edition-2017 - 3500Na B	mg/L	25	-	-
16	Pottasium	APHA 23rd Edition 2017- 3500-K B	mg/L	2	-	-
17	Residual Chlorine	IS/APHA	mg/L	0	0.2	1
18	Fecal Coliform	IS/APHA	CFU/100ml	0	--	--

Report: The tested sample Conformed to IS: 10500:2012 drinking water specification with respect to above tested parameters.

.....End of the report.....

Authorised Signatory

S.Kathirkamanathan, B.Sc., MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.

Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvapur (Dt).

Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvapur (Dt).



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram,

Thiruvarur – 610001.

Phone: 04366-221300

E-mail: dwtlthiruvarur@gmail.com



TC – 10751

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25433	Report Issue Date :	27.01.2026	Page No : 01 of 01		
Invoice Details:	0121/Dt.23.01. 2026/Amt.Rs.1652/-	ULR No	TC1075126000000276F			
Client Name & Address : Concordia Public School, Contact No / Email.ID : 763,Mela Kadu,Near Alagar Nagar, Karikottai,Mannargudi.						
Sample Name	: Water					
Sample Number	: 25433					
Sample Description	: Bore Well					
Sample Submitted by	: Bakkiya					
Location & Date	: Inside The Campus & 23.01.2026					
Quantity of sample Received	: 2 Litre					
Sample Container	: Jerry Cane					
Sample Condition on Receipt	: Good					
Sample Received On	: 23/01/2026	Environmental Condition	: 23.0°C – 27.0°C			
Test Commenced on	: 23/01/2026	Test Completed on	: 27/01/2026			
S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	7.26	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	216	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-2023	172	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	20	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24 Sec -01 -2022	68	200	400
6	Nitrate as NO ₃	mg/L	APHA 24th Edition 2023– 4500 –NO3 B	4	45	45
7	Fluoride as F	mg/L	APHA 24th Edition 2023 – 4500- F-D	0.18	1.0	1.5

Remark: The tested sample Not Conformed to IS: 10500:2012 Drinking water specification with respect to above tested parameters.

.... End of the report....

Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.

Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram, Thiruvarur – 610001.

Phone: 04366-221300

E-mail: dwtlthiruvarur@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25433	Report Issue Date :	27.01.2026	Page 1 of 2
Invoice Details:	0121/Dt.23.01. 2026/Amt.Rs.1652/-			

Client Name & Address Contact No / Email.ID	: Concordia Public School, 763,Mela Kadu, Near Alagar Nagar, Karikottai,Mannargudi.
Sample Name	: Water
Sample Number	: 25433
Sample Description	: Bore Well
Sample Submitted by	: Bakkiya
Location & Date	: Inside The Campus & 23.01.2026
Quantity of sample Received	: 2 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 23/01/2026
Test Commenced on	: 23/01/2026
Test Completed on	: 27/01/2026
Environmental Condition	: 23.0°C – 27.0°C

S. No	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Colour	IS 3025 Part 4 - 2022	HU	5	5	15
3	Odour	IS 3025 Part 5: 1983	--	None	Agreeable	Agreeable
4	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.3	1	5
5	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	361	500	2000
6	Conductivity	APHA 23rd Edition 2017 – 2510 B	μS/cm	515	-	-
7	P - Alkalinity	IS 3025–Part 23-1983	mg/L	6	-	-
8	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	86	70	200
9	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	31	30	100

Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.

Principal

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).

Correspondent

CONCORDIA PUBLIC SCHOOL
Affiliated to CBSE - Affiliation No. 1931744
No.763, Melakadu
Karakkottai (Po) - 614 013
Mannargudi (Tk), Thiruvarur (Dt).



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
No. 25, Perumal Vadakku Theru, Madapuram, Thiruvavarur – 610001.
Phone: 04366-221300 E-mail: dwtlthiruvavarur@gmail.com

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25433	Report Issue Date :	27.01.2026	Page 2 of 2
Invoice Details:	0121/Dt.23.01. 2026/Amt.Rs.1652/-			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
10	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1
11	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0.00	0.1	0.3
12	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0.14	0.5	0.5
13	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO ₂ B	mg/L	0.00	-	-
14	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0.00	-	-
15	Sodium	APHA 23rd Edition-2017 – 3500Na B	mg/L	51	-	-
16	Pottasium	APHA 23rd Edition 2017– 3500-K B	mg/L	5	-	-
17	Residual Chlorine	IS/APHA	mg/L	0	0.2	1
18	Fecal Coliform	IS/APHA	CFU/100ml	340	--	--

Report: The tested sample Not Conformed to IS: 10500:2012 drinking water specification with respect to above tested parameters.


.....End of the report.....


 Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.


 Principal

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvavarur (Dt).


 Correspondent

CONCORDIA PUBLIC SCHOOL
 Affiliated to CBSE - Affiliation No. 1931744
 No.763, Melakadu
 Karakkottai (Po) - 614 013
 Mannargudi (Tk), Thiruvavarur (Dt).